

Energy and Green Audit Report

August - 2023



**Shri Madhwa Vadiraja Institute of Technology & Management,
Udupi, Karnataka**

Bigeta Energy Solutions LLP

Bengaluru
bigetaenergy.com


Principal
SHRI MADHWA VADIRAJA
INSTITUTE OF TECHNOLOGY & MANAGEMENT
Vishwothama Nagar, Udupi Dist.
BANTAKAL, STATION

Acknowledgement

Bigeta Energy Solutions is thankful to Shri Madhwa Vadiraja Institute of Technology & Management for providing us an opportunity to conduct an energy and green audit at their institution located in Vishwothama Nagar, Bantakal, Udupi, Karnataka. We are grateful to Dr.Thirumaleshwara Bhat - Principal, Dr.Ganesh Aithal - Vice Principal, Dr. Sudarshan Rao - Dean (Quality Assurance), Mr. Vinayaka - Maintenance Engineer, and the other staff members for their active involvement and support during the audit process.

We hope you find the recommendations provided in the report helpful in saving energy and improving sustainability. While we have made every effort to adhere to high quality standards in both data gathering analysis and report presentation, we would appreciate any comments from your side on how we may improve even further.

BENET GEORGE Digitally signed by
BENET GEORGE
VADAKKEMUL VADAKKEMULANJANAL
ANJANAL Date: 2023.09.16
11:08:44 +05'30'

In case of any suggestions or queries:

Bigeta Energy Solutions LLP

Mr. Benet George V

BEE Accredited Energy Auditor

Email: benet@bigetaenergy.com

Mobile- +91 99005 91000

#1489, Sy No.476/3, Sarjapur-Attibele Road,

Sarjapura, Bengaluru, Karnataka 562 125

Contents

| | | |
|------------|-------------------------------------------------------------------|-----------|
| 1.0 | Introduction | 5 |
| 1.1 | About the college | 6 |
| 1.2 | Vision and Mission..... | 7 |
| 1.3 | Infrastructure | 7 |
| 1.4 | Energy and Green Audit | 8 |
| 1.5 | Energy Audit methodology..... | 8 |
| 1.6 | List of faculties and students who participated in the Audit..... | 9 |
| 2.0 | Energy Audit | 13 |
| 2.1 | Executive summary | 13 |
| 2.2 | Impact of proposed Energy conservation measures..... | 13 |
| 2.3 | Summary of Energy Conservation Measures | 15 |
| 2.4 | Marginal cost of electrical energy | 17 |
| 2.5 | Good Practices..... | 17 |
| 3.0 | Energy Conservation Measures (ECM) | 18 |
| 3.1 | STP Treatment Plant..... | 18 |
| 3.2 | Water system | 19 |
| 3.3 | Lighting System | 23 |
| 3.4 | Ceiling Fans..... | 25 |
| 3.5 | Canteen | 27 |
| 3.6 | Air Conditioners..... | 29 |
| 4.0 | Observation and Analysis | 31 |
| 4.1 | Electricity supply and Network..... | 31 |
| 4.2 | Capacitor banks | 34 |
| 4.3 | Air Conditioners..... | 35 |
| 4.4 | Pumps..... | 36 |
| 5.0 | Electrical Graphs | 38 |
| 5.1 | Main incomer 500 KVA Transformer | 38 |
| 6.0 | Green Audit | 41 |
| 6.1 | Waste Management | 41 |
| 6.2 | Water Management | 45 |

| | | |
|------------|-----------------------------------------|-----------|
| 7.0 | Biodiversity | 49 |
| 8.0 | Carbon Foot Print Analysis | 53 |

List of Tables

| | | |
|-----------|-------------------------------------------------------------------------------------------|----|
| Table 1. | Student's details | 6 |
| Table 2. | Faculty details | 7 |
| Table 3. | List of faculty members involved in Audit process | 9 |
| Table 4. | List of students who participated in the audit | 9 |
| Table 5. | Carbon (CO ₂) offset | 10 |
| Table 6. | Summary of Energy Conservation Measures | 15 |
| Table 1. | Marginal cost of Energy | 17 |
| Table 2. | Cost benefit analysis for optimized operation of STP aerator air blower | 19 |
| Table 3. | Cost benefit analysis for automatic water over flow control | 20 |
| Table 4. | Cost benefit analysis for replacement of CFL lights to LED lights | 23 |
| Table 5. | Cost benefit analysis for install motion sensors for Corridors & Rest room in hostel | 25 |
| Table 6. | Cost Benefit analysis for replacement of existing ceiling fans to BLDC fans in hostels | 26 |
| Table 7. | Cost Benefit analysis for replacement of existing ceiling fans to BLDC fans in all blocks | 27 |
| Table 8. | Cost benefit analysis for install solar water heater | 28 |
| Table 9. | Cost benefit analysis for Install Biogas plant for Canteen | 29 |
| Table 10. | Cost benefit analysis for replacement of existing AC to 5-star rated AC's | 30 |
| Table 11. | EB Bill Analysis | 32 |
| Table 12. | Capacitor bank individual phase current measurement | 34 |
| Table 13. | Performance assessment of Air conditioners | 35 |
| Table 14. | Performance assessment for Bore well pumps | 37 |
| Table 15. | Waste generation | 42 |
| Table 16. | Water test results | 46 |
| Table 17. | Floral species in the campus | 49 |
| Table 18. | Faunal species in the campus | 51 |
| Table 19. | Carbon Foot Print Analysis | 53 |

List of Figures

| | | |
|------------|-----------------------------------------------------|----|
| Figure 1. | Location of College | 7 |
| Figure 2. | Opening meeting | 8 |
| Figure 3. | Sewage treatment plant | 18 |
| Figure 4. | Automatic water overflow control for overhead tanks | 20 |
| Figure 5. | Taps photos in institution | 21 |
| Figure 6. | High-pressure water nozzles | 22 |
| Figure 7. | Energy saving posters in class room and corridors | 24 |
| Figure 8. | Canteen Food waste | 28 |
| Figure 9. | Annual Contract demand, Record Demand | 33 |
| Figure 10. | EB consumption Vs Solar generation | 33 |

| | | |
|------------|-----------------------------------|----|
| Figure 11. | Solar Export Vs generation | 34 |
| Figure 12. | Voltage profile for main incomer | 38 |
| Figure 13. | Current profile for main incomer | 38 |
| Figure 14. | Power profile for main incomer | 39 |
| Figure 15. | Current Unbalance in main incomer | 39 |
| Figure 16. | Types of waste generated | 41 |
| Figure 17. | Total waste generation | 43 |
| Figure 18. | Strategies need to be implemented | 44 |
| Figure 19. | STP Water Quality test report | 46 |
| Figure 20. | Water Quality test report canteen | 47 |
| Figure 21. | Best Practices | 47 |
| Figure 22. | Processes in need of improvement | 48 |
| Figure 23. | Flora and Fauna in the campus | 52 |

1.0 Introduction

The working details of assignment are as follows:

| | |
|-----------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------|
| Project | Energy and Green Audit |
| Client | Shri Madhwa Vadiraja Institute of Technology & Management |
| Industry | Engineering College Dr. Sudarshan Rao K Dean (Quality Assurance) |
| Contact | Mobile- +91 9448252890 Email: qa@sode-edu.in |
| Site | Vishwothama Nagar, Bantakal, Udupi, Karnataka - 574115 |
| Consultant | Bigeta Energy Solutions LLP Bangalore, India |
| Duration | 28 and 29-Aug-2023 |
| Project Scope | To conduct energy and green audit at Shri Madhwa Vadiraja Institute of Technology & Management |
| Report | This document gives recommendations, details of findings and the way forward. |
| Consultants involved | Mr. Benet George V - BEE Accredited Energy Auditor- AEA0053 Dr. Ganapathi A (EA-34973/23) Alwar Purushotham - Sr.Engineer |
| Notes | The suggestions / alternatives in the audit report are based on the present operating conditions of equipment/systems and to the best of our knowledge. |

1.1 About the college

Shri Madhwa Vadiraja Institute of Technology and Management, established in Bantakal in 2010, is managed by Shri Sode Vadiraja Mutt Education Trust, Udupi. It is represented by its present head, Shree Vishwa Vallabha Theertha Swamiji. The trust was registered on October 29, 2009, as a charitable trust under the Indian Trusts Act 1882. The trust is set up with the express objective of promoting educational and research activities in the rural areas of the country.

More than 1200 students are currently pursuing engineering degrees in the fields of computer science, electronics and communication, mechanical engineering, and civil engineering. In terms of infrastructure, SMVITM is comparable to other well-established engineering colleges in the region.

The institution is getting power from Mangalore Electricity Supply Company Ltd. (MESCL). Electricity is received at 11 kV, and a 500 kVA transformer is installed in the institution to step down the incoming 11 kV supply to 433 kV. Other than the EB power supply, there are two DG's of 160 kVA and 62.5 kVA in the institution to generate power in case of EB power failure. The institute has also installed a 125-kW solar system to generate electricity.

Major Loads in the Institution:

- ❖ Fans and Lights
- ❖ Air Conditioners
- ❖ UPS
- ❖ Computers
- ❖ Pumps
- ❖ Air Blowers

Table 1. Student's details

| Programme | | From the state where College is located | From other states of India | NRI students | Foreign students | Total |
|-----------|--------|-----------------------------------------|----------------------------|--------------|------------------|-------|
| UG | Male | 669 | 25 | 1 | 0 | 695 |
| | Female | 580 | 5 | 0 | 0 | 585 |
| | Others | 0 | 0 | 0 | 0 | 0 |

Table 2. Faculty details

| Highest Qualification | Professor | | | Associate Professor | | | Assistant Professor | | | Total |
|-----------------------|-----------|--------|--------|---------------------|--------|--------|---------------------|--------|--------|-------|
| | Male | Female | Others | Male | Female | Others | Male | Female | Others | |
| Ph.D. | 5 | 0 | 0 | 3 | 5 | 0 | 4 | 2 | 0 | 19 |
| PG | 2 | 0 | 0 | 1 | 0 | 0 | 21 | 33 | 0 | 57 |

There are 1280 students enrolled in the college's undergraduate programs, which include CSE, ECE, MECH, CIVIL, AIML, and AIDS. In addition, the College confers Ph.D. degrees, and it has 76 faculty members.

1.2 Vision and Mission

Vision


To establish an excellent, value-based higher educational hub to meet the challenges of global competitiveness.

Mission

To impart holistic education with state-of-the-art infrastructural facilities and conducive academic ambience, at affordable costs, leading to the creation of centres of excellence with best brains collectively interacting for total personality development and intellectual growth.

1.3 Infrastructure

Figure 1. Location of College



The college has a total built-up area of 74460.06 square meters, and it has all of the necessary physical amenities.

1.4 Energy and Green Audit

Detailed energy and green audit fieldwork has been conducted during 28th and 29th, August 2023. In addition to external team, staff and students also involved in the audit.

1.5 Energy Audit methodology

Phase 1 - Pre-Audit

Campus details, energy consumption details, etc. are collected, analyzed, and planned for field work. Based on the initial details, two days of field work are planned.

Phase 2 - Field work and data collection

On the first day, the opening meeting was done, and key stakeholders and members of the management team were present. The purpose of the audit, methodology, and activities planned were explained. Student volunteers were selected for data collection. Field visits, interviews, data verification, and spot measurements are done. The closing meeting to discuss the initial findings and observations is done on the final day of the field work.

Figure 2. Opening meeting



Phase 3 - Report

Analysis of the data and preparation of the report.

1.6 List of faculties and students who participated in the Audit

Table 3. List of faculty members involved in Audit process

| S. No. | Name | Designation |
|--------|--------------------------|--------------------------|
| 1 | Dr. Thirumaleshwara Bhat | Principal |
| 2 | Dr. Ganesh Aithal | Vice Principal |
| 3 | Dr. Sudarshan Rao K | Dear (Quality Assurance) |
| 4 | Mr. Vinayaka | Maintenance Engineer |
| 5 | Mr. Dinesh Kumar | Maintenance Assistant |
| 6 | Mr. Sathish Bangera | Electrician |

Table 4. List of students who participated in the audit


| S.No | Student Name | Year | Reg. No | Team |
|------|-------------------|------|------------|---------------|
| 1 | Dhanish Mohammed | II | 4MW21ME004 | Energy Audit |
| 2 | S.Chetam | II | 4MW22ME402 | |
| 3 | kitan Avari | II | 4MW21ME009 | |
| 4 | Guru Kiran B | II | 4MW21ME400 | |
| 5 | Sagar | II | 4MW21CV007 | |
| 6 | K.Sathvik Acharya | II | 4MW21CV003 | |
| 7 | Aryan Raj | II | 4MW21CV001 | Bio Diversity |
| 8 | Likhith Yermal | II | 4MW21ME010 | |
| 9 | Gagan Kumar | II | 4MW21ME005 | |
| 10 | Annapa | II | 4MW22CV400 | |
| 11 | Rohith | II | 4MW22ME401 | |
| 12 | Shiv preeth | II | 4MW22ME403 | |

The above faculties and students actively participated in this energy and green audit conducted at SMVITM. The students are divided into two teams: energy and biodiversity. Each team was tasked with gathering the necessary data for energy management and biodiversity. Students' data was analyzed with the goal of proposing conservation and improvement strategies to enable the college to maintain a green and sustainable campus.


Table 5. Carbon (CO₂) offset

| Sl. No | Description | Type of Energy and their CO ₂ Conversion Process | | | |
|--------|---------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|-----------------------------|------------------------|------------------|
| | | Electricity kWh | Diesel (Vehicle + DG) Litre | Petrol (Vehicle) Litre | LPG kg |
| 1 | Annual Consumption | 215693 | 27655 | 430 | 6400 |
| 2 | CO ₂ Emission (Tons/Annum) | 177 | 73 | 1 | 19 |
| 3 | Total CO₂ Emission (Tons/Annum) | | | | 270 (↑) |
| 4 | No. of Matured Trees Available | | | | 700 |
| 5 | CO ₂ offset due to Trees (Tons/Annum) | | | | 15.26 (↓) |
| 6 | Annual Energy Exported from SPV Plant (kWh) | | | | 29982 |
| 7 | CO ₂ offset due to export Solar Power Plant (Tons/Annum) | | | | 25 (↓) |
| 8 | CO ₂ Emission per (Tons/Annum) currently | | | | 230 (↑) |
| 9 | Expected Reduction of Annual Electricity Consumption after Implementing Proposed Energy Conservation Measures (kWh) | | | | 95438 |
| 10 | CO ₂ offset after implementing ECM (Tons/Annum) | | | | 78.3 (↓) |
| 11 | Expected Reduction of Annual LPG Consumption after Implementing Proposed ECM (kgs) | | | | 1232 (↓) |
| 12 | CO ₂ offset after implementing biogas plant instead of LPG (Tons/Annum) | | | | 3.7 (↓) |
| 13 | Amount of CO ₂ to be offset final (Tons/Annum) | | | | 82 (↔) |
| 14 | Per Capita CO ₂ Consumption (Tons/Annum) | | | | 0.116 |

- ❖ Apart from energy conservation and environmental analysis, the audit team proposes technical recommendations focusing on energy, water, environmental, safety, and best operating practices to be followed.




CO₂ emission
270 Tons/Annum



CO₂ offset due to Trees
15.26 Tons/Annum



**CO₂ offset due to solar plant
25 Tons/Annum**



**CO₂ offset after implementing ECM
82 Tons/Annum**

Princip
Principal

**SHRI MADHWA VADIRAJA
INSTITUTE OF TECHNOLOGY & MANAGEMENT**
Vishwothama Nagar, Udupi Dist.
BANTAKAL - 574 115

ENERGY AUDIT



2.0 Energy Audit

An energy audit is an inspection, survey, and analysis of energy flow for energy conservation in a building, process, or system to reduce the amount of energy input into the system without negatively affecting the output. The energy audit consists of a detailed examination of how a facility uses energy and what it pays for the energy that is consumed. Reducing energy consumption while maintaining or improving human comfort, health, and safety are of primary concern. The primary objective of an energy audit is to determine ways to reduce energy consumption per unit of product output or lower operating costs. An energy audit provides a "benchmark" for managing energy in the organization and provides the basis for planning a more effective use of energy throughout the organization. Therefore, by conducting an energy audit program, the overall efficiency of a system can be improved.


2.1 Executive summary

2.1.1 Highlights


| | | | |
|------------------------------------------------------|---|--------|-----------|
| Total annual cost savings | = | 11 | Rs. Lakhs |
| Total investments | = | 38 | Rs. Lakhs |
| Overall simple payback period | = | 42 | Months |
| Annual Electrical Energy Consumption (Sep-22-Aug-23) | = | 215693 | kWh |
| Annual Electricity cost | = | 20.3 | Rs. Lakhs |
| Solar generation (Sep-22 -Aug-23) | = | 163700 | kWh |

2.2 Impact of proposed Energy conservation measures


| | | | |
|---------------------------|---|--------|--------------|
| Electricity Savings | = | 95,438 | kWh/annum |
| | = | 27 | % |
| Annual cost reduction | = | 11 | Rs. Lakhs |
| | = | 52 | % |
| Co ₂ reduction | = | 13 | Tonnes/Annum |



Electricity Savings
95,438 KWh



Investment
38 lakhs



Cost Reduction
11 lakhs



CO₂ Reduction
13 Tonnes/Annum

2.3 Summary of Energy Conservation Measures

Table 6. Summary of Energy Conservation Measures

| S. No. | Energy Conservation Measures | Annual Savings | | | | Investment | Simple Payback Period | CO ₂ Reduction |
|---------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------|----------|----------------------|-----------|------------|-----------------------|---------------------------|
| | | kWh | LPG (Kg) | Water (Lakhs Litres) | Rs. Lakhs | Rs. Lakhs | Months | (Tons/Annum) |
| 0-35 months payback | | | | | | | | |
| 1 | <p>Optimized operation of the STP aerator blower motor by an interlock mechanism for nighttime operation</p> <p>Currently, two 5.5 KW rated air blower motors are installed. It's operating 12 hours per day. Optimize the operation of the air blower for 2 hours at night.</p> | 4191 | - | - | 0.42 | 0.10 | 3 | 3.6 |
| 2 | <p>Install an automatic water overflow controller or monitor in overhead tanks to reduce the water overflow in all buildings.</p> <p>At present, there are ten tanks with a capacity of 10,000 litres and one with a capacity of 5,000 litres. It's filled twice a day, and there is no control over overflow of water.</p> | - | - | 3 | | 0.20 | 13 | |
| 3 | <p>Replacement of existing CFL lights to LED lights</p> <p>At present, all blocks in the institution (Admin, Civil & Mech, EC, AIDS, and Library) have a total of 845 CFL (23 W) lights installed. Change to LED lights.</p> | 19874 | - | - | 1.99 | 2.88 | 17 | 0.11 |
| 4 | <p>Replacement of existing conventional ceiling fans with BLDC fans in Boys and Girls hostels</p> <p>Boys hostels (I and II) and girls hostels have around 223 conventional ceiling fans installed. Replace the ceiling fans with BLDC fans.</p> | 21453 | - | - | 2.15 | 5.58 | 31 | 18.23 |
| 5 | <p>Install a solar water heater instead of using LPG to boil the water for rice cooking in the canteen.</p> | - | 118 | - | 0.11 | 0.30 | 34 | - |

| S. No. | Energy Conservation Measures | Annual Savings | | | | Investment | Simple Payback Period | CO ₂ Reduction |
|--------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------|-------------|----------------------|-----------|------------|-----------------------|---------------------------|
| | | kWh | LPG (Kg) | Water (Lakhs Litres) | Rs. Lakhs | Rs. Lakhs | Months | (Tons/Annum) |
| | The canteen uses LPG to boil water for rice. Install the solar water heater to boil the water and reduce the consumption of LPG. | | | | | | | |
| 6 | Install water-efficient high-pressure nozzles in canteens and vehicles for cleaning. In the canteen and nearer to the DG room, taps are used to clean the vessels and vehicles with high-pressure pipes. Install water-efficient, high-pressure nozzles to reduce water consumption. | - | - | 11 | - | 0.05 | - | - |
| 7 | Install a biogas plant for food waste Canteen food waste is around 60 kg/day. Install a biogas plant to reduce LPG gas usage. | - | 1232 | - | 1.15 | 2.05 | 21 | - |
| >36 months payback | | | | | | | | |
| 8 | Replacement of existing 2/3-star-rated AC units with 5-star inverter AC units Existing 2/3-star older ACs in all block should be replaced with 5-star-rated inverter AC units as they age and have higher power consumption. | 18820 | | | 1.88 | 9.90 | 63 | 16.00 |
| 9 | Replacement of existing conventional ceiling fans to BLDC fans in all blocks At present, all blocks have around 646 conventional ceiling fans installed. Replace the ceiling fans with EC-BLDC fans. | 30117 | | | 3.02 | 16.15 | 64 | 25.60 |
| 10 | Install motion and occupancy sensors in corridors and rest rooms in boys and girls hostels. It is recommended to install motion and occupancy sensors in corridors and rest rooms in boys and girls hostels to reduce their operation when unoccupied. | 983 | | | 0.10 | 0.35 | 43 | 0.84 |
| Total | | 95438 | 1350 | 13 | 11 | 38 | 42 | 13 |

2.4 Marginal cost of electrical energy

Electrical marginal energy charges typically include the sources of energy and their corresponding charges (like EB, DG, and green energy—wheeled). Since the proportion of annual DG is lower, the cost of energy due to it is neglected.

Table 1. Marginal cost of Energy

| Description | Unit | Value |
|----------------------------|---------|-------|
| Energy consumption | kWh | 20274 |
| Energy charge | Rs./kWh | 8.5 |
| other charges | Rs./kWh | 0.75 |
| Tax (@9% of Energy charge) | % | 0.77 |
| Marginal Energy Cost | Rs./kWh | 10.02 |

Note: unit charge taken based on latest bill

2.5 Good Practices

- ❖ A 125-KW rooftop solar plant is installed on campus as an alternate renewable source of energy.
- ❖ In Boys & Girls Hostel, exiting tube lights are changed to 9-W LED lights when they fail.
- ❖ Energy conservation practices, such as switching off the AC and fans when not required, are encouraged.
- ❖ Faculty and students are encouraged to come by EV and CNG vehicles.
- ❖ Conducting seminars every year on the topic of energy conservation.
- ❖ The Environment Club of SMVITM is conducting a workshop on paper pen making for the students of SVH Kannada High School, Innanje on the school premises.
- ❖ Every year, students celebrate World Environment Day and conduct seminars.

3.0 Energy Conservation Measures (ECM)


3.1 STP Treatment Plant

3.1.1 Optimized operation of the STP aerator blower motor by an interlock mechanism for nighttime operation

Background & Findings

- ❖ The institution is equipped with a 120 KLD capacity sewage treatment plant (STP) operating 24 hours a day.
- ❖ Two air blowers' same capacity (same air flow rate) are connected in the sewage treatment plant, supplying air to the aerator tank.
- ❖ The capacity of the air blowers is 5.5 KW/7.5 HP motors operating 12 hours each alternately in a day.
- ❖ The main purpose of an air blower is to supply oxygen (from ambient air) in order to maintain the BOD level.

Figure 3. Sewage treatment plant



Recommendation:

- ❖ Load in the STP is variable based on the people at campus. Also the actual flow to the STP is lower than the design capacity. Hence air required at STP varies with respect to time. Considering this intermittent operation during night and weekends will save energy without affecting the performance of the STP.

- ❖ During the night, it is better to operate the motor for 45 minutes and 15 minutes off (for 1 hour of operation). It can be done from 10 p.m. to 6 p.m., resulting in 2 hours of run-time savings directly.

Benefit:

cost benefit analysis is given in the table below

Table 2. Cost benefit analysis for optimized operation of STP aerator air blower

| Description | Unit | Air blower |
|-------------------------------------------------------------|-----------|------------|
| Present system | | |
| Total no of units operating | No's | 1 |
| Motor rated | kW | 5.5 |
| Motor Efficiency | % | 86 |
| Average power consumption | kW | 6.2 |
| Loading | % | 113 |
| Operating Hrs per day | Hrs | 12 |
| Annual operating days | Days | 260 |
| Annual Energy consumption | kWh | 19.34 |
| Proposed system-optimize the operation of Air blower | | |
| Reduce the operating hours | Hrs | 2 |
| Energy consumption/day | kWh/day | 3.22 |
| Estimated Annual Energy savings | kWh/annum | 4191.20 |
| Energy cost | Rs./kWh | 10.02 |
| Annual cost savings | Rs. Lakhs | 0.4197 |
| Investment | Rs. Lakhs | 0.1 |
| Payback | months | 3 |
| CO ₂ Reduction | Ton/Annum | 3.6 |

3.2 Water system

3.2.1 Install an automatic water overflow controller or monitor in overhead tanks to reduce the water overflow in all buildings.

Background

- ❖ At present, there are ten tanks with a capacity of 10,000 litres and one with a capacity of 5,000 litres. It's filled twice a day, and there is no control over overflow of water.


Findings:

- ❖ During the audit, it was observed that overhead tanks in boys and girls hostels overflow for at least 10 minutes.
- ❖ Overhand tanks have no water overflow control. It's wasting water and energy.

Recommendation:

- ❖ Install automatic water overflow control for overhead tanks in all buildings. It will control the water flow and reduce water waste and energy.

Figure 4. Automatic water overflow control for overhead tanks



Benefit:

Table 3. Cost benefit analysis for automatic water over flow control

| Description | Unit | Flow controller |
|------------------------------------------|------|-----------------|
| No. of in tanks of Hostel (Boys & Girls) | No's | 4 |
| No. of in tanks of Admin Block | No's | 2 |
| No. of in tanks of Civil/Mech Dept | No's | 1 |
| No. of in tanks of Canteen | No's | 1 |
| No. of in tanks of AIDS Block | No's | 1 |
| No. of in tanks of EC Block | No's | 1 |
| Flow rate of water | lpm | 10 |
| Average Time of overflow (2 times a day) | mins | 10 |

| Description | Unit | Flow controller |
|-----------------------------------------------------------------|-------------|-----------------|
| Total over flow of water | litres | 1000 |
| Assessment of Motor power for pumping 500litres of water | | |
| Power consumed per m3 of water | kW | 0.6 |
| Power Savings for reduction in water consumption | kW | 0.6 |
| Annual power Savings (260 days) | kW | 156 |
| Cost of one unit of electricity | Rs | 10.02 |
| Total Cost Savings per year | Rs. Lakhs | 0.016 |
| Investment | Rs. Lakhs | 0.2 |
| Payback Period | Months | 12.79 |
| Water Savings per Year | Lakh litres | 2.6 |

3.2.2 Install water efficient high-pressure nozzles in canteen & Vehicle cleaning

Background & Findings

- ❖ In canteen, taps are used to clean vessels and are operated for 5 hours a day.


Figure 5. *Taps photos in institution*



Recommendation:

- ❖ To reduce the water consumption from this tap, install the high-pressure water nozzles in the canteen and vehicles cleaning.
- ❖ It will reduce the water consumption by 50% operate with low pressure.

Figure 6. High-pressure water nozzles



Benefit:

cost benefit analysis is given in the table below

| Description | Unit | values |
|-----------------------------------------------------------------|-------------|--------|
| No of open Valves in canteen | Nos | 3 |
| Flow rate of water | lpm | 15 |
| Average open time per day | mins | 300 |
| Total flow of water | litres | 13500 |
| Average water Saving due to Nozzle | % | 60 |
| Total Water Savings per day | lts | 8100 |
| Assessment of Motor power for pumping 500litres of water | | |
| Power consumed per m3 of water | kW | 0.6 |
| Power Savings for reduction in water consumption | kW | 4.86 |
| Annual power Savings (260 days) | kW | 1263.6 |
| Power consumed by Dish washer per day | kW | 1 |
| Annual power Consumption by dish washer | kW | 260 |
| Annual Power Savings | kW | 1003.6 |
| Cost of one unit of electricity | Rs | 10.02 |
| Annual Power Savings | kW | 10056 |
| Investment | Rs. Lakhs | 0.05 |
| Payback Period | Months | 0.00 |
| Water Savings per Year | lakh Litres | 10.53 |

Note: For calculation we consider only 3 taps

Option-2

- ❖ Install an automatic dishwashing machine in the canteen to reduce water consumption. The payback period will be high, but water will save nearly 5.85 lakh litres.

❖ *Automatic Dish washing machine*



3.3 Lighting System

3.3.1 Replacement of existing CFL lights to LED lights

Background & Findings

- ❖ At present, institutional existing CFL lights (23 W) are around 845 No's.
- ❖ Existing lights in Boys and Girls Hostels have already been replaced with LED lights (9W). It is good practice.

Recommendation:

- ❖ Replace the existing CFL lights with LED lights (9W). It will reduce energy consumption without changing the illumination.

Benefit:

cost benefit analysis is given in the table below

Table 4. Cost benefit analysis for replacement of CFL lights to LED lights

| Description | Unit | Value |
|---------------------------------------|------|-------|
| Present system | | |
| Total no. of CFL lights in all blocks | No's | 845 |
| Average light fitting wattage | W | 23 |
| Operating Hours | hrs | 8 |
| Annual Operating Days | days | 210 |
| Annual Energy Consumption | kWh | 32651 |

| Description | Unit | Value |
|----------------------------------------------------------|-----------|-------|
| Proposed system - CFL lights change to LED lights | | |
| LED lights Average fitting wattage | W | 9 |
| Annual Energy Consumption | kWh | 12776 |
| Estimated annual Energy savings | kWh/annum | 19874 |
| Energy cost | Rs./kWh | 10 |
| Estimated annual cost savings | Rs. Lakhs | 2 |
| Total investment | Rs. Lakhs | 2.88 |
| Simple payback period | months | 17 |
| CO ₂ Reduction | Ton/Annum | 0.11 |

3.3.2 Install motion and occupancy sensors in corridors and rest rooms in boys and girls hostels


Background & Findings

- ❖ At present, hostels (boys and girls) corridors and rest rooms are using lights continuously throughout the night.

Recommendation:

- ❖ Install a motion/occupancy sensor in corridors and rest rooms.
- ❖ Management has to create awareness about energy savings among students and staff and provide posters in all class rooms and corridors.

Figure 7. *Energy saving posters in class room and corridors*



Benefit:

cost benefit analysis is given in the table below

Table 5. Cost benefit analysis for install motion sensors for Corridors & Rest room in hostel

| Description | Unit | Value |
|---------------------------------------------------|-----------|-----------------------|
| Present system | | Rest room & corridors |
| Total no. of lights | No's | 50 |
| Average light fitting wattage | W | 9 |
| Operating Hours | hrs | 12 |
| Annual Operating Days | days | 260 |
| Annual Energy Consumption | kWh | 1404 |
| Proposed system - Install Occupancy/motion sensor | | |
| Estimated Annual Energy Savings* | kWh | 983 |
| Energy cost | Rs./kWh | 10.0 |
| Estimated annual cost savings | Rs. Lakhs | 0.10 |
| Estimated investment for motion sensors | Rs. Lakhs | 0.35 |
| Simple payback period | months | 43 |
| CO ₂ Reduction | Ton/Annum | 0.84 |

Note: For calculation we consider Average lights remaining Emergency lights

3.4 Ceiling Fans

3.4.1 Replacement of existing conventional ceiling fans with BLDC fans in Boys and Girls hostels

Background & Findings

- ❖ According to data provided by the institution, there are approximately 223 conventional ceiling fans in the boys and girls hostels.
- ❖ Conventional fans consume 60 W–70 W during operation.

Recommendation:

- ❖ Replace the existing conventional fans with EC-BLDC fans in hostels in a phased manner and ensure good energy savings.
- ❖ BLDC fans operate with less energy and the same air delivery. Similarly, these fans generate less noise, run with an inverter supply, and have remote control-based speed control.
- ❖ BLDCF fans consume 1 unit of electricity for nearly 28-29 hours.

Benefit:

cost benefit analysis is given in the table below

Table 6. Cost Benefit analysis for replacement of existing ceiling fans to BLDC fans in hostels

| Description | Units | value |
|---------------------------------|-----------|---------|
| Present condition | | |
| No's of fans existing | No's | 223 |
| Power consumption | kW | 0.07 |
| Average No of hour working | Hrs | 10 |
| Annual No. of operating days | Days | 260 |
| Annual Energy consumption | kWh/annum | 37687 |
| Proposed Condition | | |
| Replace to BLDC fan | | |
| power consumption for BLDC fans | kW | 0.028 |
| Annual Energy consumption | kWh/annum | 16234.4 |
| Estimated annual Energy savings | kWh/annum | 21452.6 |
| Energy cost | Rs. | 10.0 |
| Total savings | Rs. Lakhs | 2.1 |
| Total investment | Rs. Lakhs | 5.58 |
| Payback period | Months | 31 |
| CO ₂ Reduction | Ton/Annum | 18 |

Note: This Recommendation more beneficial for HT consumer as direct reduction of KVA rating

3.4.2 Replacement of existing conventional ceiling fans to BLDC fans in all blocks

Background & Findings

- ❖ According to the institution's data, all 646 units are equipped with conventional ceiling fans.

Recommendation:

- ❖ Replace the existing conventional fans with EC-BLDC fans in the institution in a phased manner and ensure good energy savings.

Benefit:

cost benefit analysis is given in the table below

Table 7. Cost Benefit analysis for replacement of existing ceiling fans to BLDC fans in all blocks

| Description | Units | value |
|---------------------------------|-----------|----------|
| Present condition | | |
| No's of fans | No's | 646 |
| Power consumption | kW | 0.07 |
| Average No of hour working | Hrs | 6 |
| Annual No. of operating days | Days | 210 |
| Annual Energy consumption | kWh/annum | 52907 |
| Proposed Condition | | |
| Change to BLDC fan | | |
| power consumption for BLDC fans | kW | 0.028 |
| Annual Energy consumption | kWh/annum | 22790.88 |
| Estimated annual Energy savings | kWh/annum | 30116.52 |
| Energy cost | Rs | 10.0 |
| Total savings | Rs. Lakhs | 3.0 |
| Total investment | Rs. Lakhs | 16.15 |
| Payback period | Months | 64 |
| CO ₂ Reduction | Ton/Annum | 26 |

Note: This Recommendation more beneficial for HT consumer as direct reduction of KVA rating

3.5 Canteen

3.5.1 Install a solar water heater instead of using LPG to boil the water for rice cooking in the canteen.

Background & Findings

- ❖ At present, in canteen, LPG gas is used to boil water for 40 kg of rice per day, so nearly 100 litres of hot water are required.

Recommendation:

- ❖ Install a solar water heater instead of using LPG to boil the water for rice. It will reduce the LPG consumption of boiling hot water.

Benefit:

cost benefit analysis is given in the table below

Table 8. Cost benefit analysis for install solar water heater

| Description | Unit | Solar Water Heater |
|-------------------------------------------------|-----------|--------------------|
| Quantity of rice cooked | kgs | 40 |
| Mass of Water required for cooking 1 kg of rice | Litres | 2.5 |
| Mass of Water required for cooking | kgs | 100 |
| Inlet temperature of cold water | Celsius | 30 |
| Outlet temperature of hot water | Celsius | 80 |
| Specific heat capacity of water | kcal/kg | 1 |
| Heat required to rise water | kcal | 5000 |
| Calorific value of LPG | kcal/kg | 11000 |
| LPG consumption /day | kgs | 0.45 |
| Annual LPG consumption saving | LPG/Annum | 118 |
| LPG cost | Rs/kgs | 90 |
| Savings per day | Rs | 41 |
| No of operating days per annum | Days | 260 |
| Total savings per annum | Rs. Lakhs | 0.11 |
| Investment | Rs. Lakhs | 0.30 |
| Payback period | months | 33.8 |


Note: Rice hot water boiling it will varies based on persons

3.5.2 Install a biogas plant for food waste

Background & Findings

- ❖ In the canteen per day, approximately 60 kg of food waste is generated (50 kg of food and 10 kg of vegetables). Currently, food waste is delivered to a nearby pig farm freely.

Figure 8. Canteen Food waste



Recommendation:

- ❖ Instead of sending food waste to a pig farm, it is suggested that a biogas plant be installed to generate methane gas.
- ❖ This methane gas can be used to cook food in canteens.
- ❖ This reduces the LPG consumption in the canteen.

Benefit:

cost benefit analysis is given in the table below

Table 9. Cost benefit analysis for Install Biogas plant for Canteen

| Description | Unit | Bio Gas Plant |
|-----------------------------------------------|---------------------|---------------|
| Daily Kitchen Waste (Food + Vegetables) | kgs | 60 |
| Annual kitchen waste (260 Days) | kgs | 15600 |
| Methane production/kg of food waste | per kg | 0.2 |
| Methane production/day | kgs | 12 |
| Total methane production per annum | kgs | 3120 |
| Calorific value of methane | kcal/m ³ | 4700 |
| Total energy content of kitchen waste per day | Kcal | 56400 |
| Calorific value of LPG | kcal/kg | 11900 |
| Quantity of LPG consumed per day in canteen | kgs | 25.4 |
| LPG savings per day | kgs | 4.74 |
| LPG savings per Annum | LPG/Annum | 1232 |
| Cost of LPG | Rs/kg | 93 |
| Total savings per day | Rs | 440.77 |
| Annual savings (260 Days) | Rs Lakhs | 1.15 |
| Investment | Rs Lakhs | 2.05 |
| Payback period | Months | 21.47 |

Note: For operating Biogas plant 1 operator is required to clean daily and fill the food waste

3.6 Air Conditioners

Background & Findings

- ❖ Administration block has 2/3-star-rated air conditioning units. A total of 22 units are installed.
- ❖ Specific energy consumption (SEC) is high for existing AC units.
- ❖ Our assessment shows an AC consumed 2.21 kW in 26°C operation; it's high in value.

Recommendation:

- ❖ It is suggested to replace the existing 2/3 star-rated AC's with 5 star-rated inverter-based AC's.
- ❖ 5-star AC's will consume 0.97 KW of power per TR.
- ❖ It will reduce the energy consumption of the air conditioners (AC).

Benefit:

cost benefit analysis is given in the table below

Table 10. Cost benefit analysis for replacement of existing AC to 5-star rated AC's

| Description | Units | Server room | AC's remaining Locations |
|-----------------------------------------------------|-------------|-------------|--------------------------|
| Present condition | | | |
| No. of AC units under operating during audit | Nos. | 1 | 20 |
| Average power consumed by the 2-star AC units | kW | 1.30 | 2.10 |
| Power consumption of 5 star rated inverter AC units | kW | 0.97 | 0.97 |
| Difference in Power Consumption | kW | 0.33 | 1.13 |
| Estimated operating hours of operation | Hrs | 24 | 6 |
| Annual No. of operating days | Days | 365 | 210 |
| Compressor Loading Percentage considered | % | 60% | 60% |
| Expected Annual Energy Saving | kWh | 1734 | 17086 |
| Energy Cost | Rs./kWh | 10 | 10 |
| Estimated Annual Cost Savings | Rs.(Lakhs) | 0.17 | 1.71 |
| Total annual Cost savings | Rs. Lakhs | 1.88 | |
| Investment (Rs. 40,000 per AC unit) | Rs. (lakhs) | 9.9 | |
| Simple payback period | months | 63 | |
| CO ₂ Reduction | Ton/Annum | 16 | |

Note: Savings estimation is based on operating hours and savings will change based on operating hours.

4.0 Observation and Analysis

4.1 Electricity supply and Network

Electricity is one of the energy sources used to meet the demands of the institution. The institution is getting power from Mangalore Electricity Supply Company Ltd. (MESCL). Electricity is received at 11 kV, and a 500 kVA transformer is installed in the institution to step down the incoming 11 kV supply to 433 kV. Other than the EB power supply, there are two DG sets of 160 kVA and 62.5 kVA installed in the institution to generate power in case of EB power failure.

The observations made during the study are given in the following sections.

4.1.1 Tariff structure of the Institution

Tariff structure of the Plant is as follows

| | | |
|--------------------------|---|-------------------------|
| ◆ Tariff Code | = | HT2C(ii) |
| ◆ Supply voltage | = | 11 kV |
| ◆ Contracted demand | = | 150 kVA |
| ◆ Minimum billing demand | = | 128 kVA (85% of CD) |
| ◆ Demand charges | = | 128 kVA=Rs. 350 per kVA |
| ◆ TOD | = | Opted |
| ◆ Energy charges | = | 8.5 Rs. /kWh. |

4.1.2 Electricity Bill Analysis The electricity bill for the 12 months (from Sep- 2022 to Aug- 2023) for the Institution was analysed and the details are tabulated as follows

Table 11. EB Bill Analysis

| Month | Contract demand | Billing Demand | Recorded Demand | Import | Export | Net Consumption | Fixed charges | Energy charges | Total Bill Amount | Solar Generation | Consumption |
|----------------|-----------------|----------------|-----------------|----------------|----------------|-----------------|---------------|-----------------|-------------------|------------------|--------------------------|
| | kVA | kVA | kVA | kWh | kWh | kWh | Rs. | Rs. | Rs. Lakhs | kWh | (Solar -Export + Import) |
| Sep-22 | 150 | 128 | 71 | 18180 | 2198.25 | 15982 | 33920 | 131050 | 1.80 | 11034 | 27016 |
| Oct-22 | 150 | 128 | 55 | 14776.5 | 3290.25 | 11486 | 33920 | 94187 | 1.42 | 12650 | 24136 |
| Nov-22 | 150 | 128 | 67 | 16094.25 | 4383.75 | 11711 | 33920 | 96026 | 1.44 | 15355 | 27066 |
| Dec-22 | 150 | 128 | 51 | 17391.75 | 1917.75 | 15474 | 33920 | 126887 | 1.79 | 12272 | 27746 |
| Jan-23 | 150 | 128 | 59 | 20810.25 | 1363.5 | 19447 | 33920 | 159463 | 2.05 | 13513 | 32960 |
| Feb-23 | 150 | 128 | 57 | 18489.75 | 2556.75 | 15933 | 33920 | 130651 | 1.74 | 14926 | 30859 |
| Mar-23 | 150 | 128 | 60 | 16557.75 | 2115 | 14443 | 33920 | 118431 | 1.61 | 13033 | 27476 |
| Apr-23 | 150 | 128 | 73 | 18699 | 3037.5 | 15662 | 33920 | 128424 | 1.74 | 17527 | 33189 |
| May-23 | 150 | 128 | 67 | 16787.25 | 3781.5 | 13006 | 33920 | 106647 | 1.36 | 16916 | 29922 |
| Jun-23 | 150 | 128 | 61 | 15773 | 3387 | 12386 | 44800 | 105281 | 1.46 | 16378 | 28764 |
| Jul-23 | 150 | 128 | 61 | 21054 | 1146 | 19908 | 44800 | 169218 | 2.21 | 11880 | 31788 |
| Aug-23 | 150 | 128 | 83 | 21079 | 805 | 20274 | 44800 | 172329 | 2.17 | 8216 | 28490 |
| Total | - | - | - | 215693 | 29982 | 185710 | 439680 | 1538594 | 20.8 | 163700 | 349410 |
| Average | - | - | 64 | 17974 | 2499 | 15476 | 36640 | 128216 | 1.7 | 13642 | 29118 |
| Min | - | - | 51 | 14776.5 | 805 | 11486.25 | 33920 | 94187.25 | 1.4 | 8216 | 24136.25 |
| Max | - | - | 83 | 21079 | 4383.75 | 20274 | 44800 | 172329 | 2.2 | 17527 | 33188.5 |

Anoop

Principal

Observation:

- ❖ Institutional contract demand is 150 kVA, and billing demand is 128 kVA (85% of CD).
- ❖ In the month of August 2023, the maximum demand was 83 kVA with a power factor of 0.96.
- ❖ 125 kW solar system generating maximum active power in the month of April 2023 is 17527 kWh.
- ❖ The maximum net consumption of the institution is 33188 kWh (Sep-2022-Aug-23).

Figure 9. Annual Contract demand, Record Demand




Figure 10. EB consumption Vs Solar generation





Figure 11. Solar Export Vs generation



4.2 Capacitor banks

The solution to improve the power factor is to add power factor correction capacitors to the institutional power distribution system. They act as reactive power generators and provide the needed reactive power to accomplish kW of work. The primary purpose of capacitors is to reduce maximum demand. This reduces the amount of reactive power, and thus total power, generated by the utilities. In the institution, one APFC panel system is installed, with a capacity of 165 kVAR.

Towards monitoring the health of the capacitors, the current of each phase of the capacitors is measured, and the details are as follows:

Table 12. Capacitor bank individual phase current measurement

| Transformer (500 kVA) Side 166 kVAR,440V | | | | | | |
|------------------------------------------|-------------------------|---------------|-------|-------|-------|---------|
| Bank S.No | Capacitor rating (kVAR) | Rated Current | R | Y | B | Remarks |
| 1 | 25 | 32.84 | 28.16 | 0.68 | 28.13 | Derated |
| 3 | 50 | 65.5 | 61.10 | 60.5 | 60.6 | Ok |
| 4 | 5 | 6.5 | 6.22 | 6.13 | 6.28 | Ok |
| 5 | 10 | 13.2 | 12.28 | 12.75 | 12.86 | Ok |
| 6 | 25 | 32.84 | 0 | 0 | 0 | Derated |
| 7 | 50 | 65.5 | 62 | 62.14 | 61.18 | Ok |
| Total | 165 kVAR | | | | | |

Observation:

- ❖ Capacitor banks 25 KVAR and 25 KVAR derated their capacity; change the capacitor banks with new ones.
- ❖ The present main incomer power factor is maintained at 0.96 average because of the solar system.

4.3 Air Conditioners

To provide cooling load for the work space, conference room, admin building, and server room, 22 units (1.5 TR and 2 TR) of individual split-type air conditioners are installed. During the audit, a sample-based performance assessment was done for operating air conditioners.

Table 13. Performance assessment of Air conditioners

| Design Parameters | Units | Server Room AC-1 | Conference Room AC-1 | Conference Room AC-2 | Boys Hostel |
|-----------------------------|-------------------|-----------------------------|-----------------------------|-----------------------------|-----------------------------|
| Type of Freezer | - | Split AC | Split AC | Split AC | Split AC |
| Make | - | Carrier | Carrier | Carrier | Carrier |
| Model No | - | 42KGL-024C+51MSG-024RA/2010 | 42KGL-024C+51MSG-018RA/2010 | 42KGL-024C+51MSG-018RA/2010 | 42KGL-024C+51MSG-024RA/2010 |
| Rated Cooling Capacity | TR | 2 | 1.5 | 1.5 | 1.5 |
| Rated Amps | A | - | - | - | - |
| AC Star rating | | 2 | 3 | 3 | 2 |
| Operating Parameters | | | | | |
| Set point | °C | 24 | 26 | 26 | - |
| Operating Hours | hrs. | 24 | 3 | 3 | 8 |
| Supply air | | | | | |
| Suction air DBT | °C | 19.4 | 13 | 20.3 | 17.3 |
| Suction air RH | % | 86.7 | 87.4 | 62.1 | 69.1 |
| Suction air WBT | °C | 17.90 | 11.82 | 15.68 | 13.90 |
| Suction air enthalpy | kJ/kg | 50.53 | 33.63 | 43.81 | 38.93 |
| Suction air density | kg/m ³ | 1.16 | 1.18 | 1.15 | 1.17 |
| Return air | | | | | |
| Return air DBT | °C | 26.9 | 25.61 | 25.61 | 25.5 |
| Return air RH | % | 59.32 | 50.14 | 50.14 | 50.6 |
| Return air WBT | °C | 21.01 | 18.41 | 18.41 | 18.4 |
| Exhaust air enthalpy | kJ/kg | 60.71 | 51.95 | 51.95 | 51.93 |
| Δ Enthalpy | kJ/kg | 10.18 | 18.32 | 8.14 | 13 |

| Design Parameters | Units | Server Room AC-1 | Conference Room AC-1 | Conference Room AC-2 | Boys Hostel |
|-------------------|--------------------|------------------|----------------------|----------------------|-------------|
| Air velocity | m/s | 1.0 | 0.7 | 0.6 | 1.1 |
| Area | m ² | 0.109 | 0.099 | 0.099 | 0.109 |
| Actual air flow | m ³ /s | 0.11 | 0.07 | 0.05 | 0.11 |
| | m ³ /hr | 384 | 255 | 196 | 411 |
| | kg/hr | 444 | 302 | 226 | 479 |
| | CFM | 226 | 150 | 115 | 242 |
| Input motor power | kW | 1.3 | 1.8 | 2 | 2.5 |
| Effective TR | TR | 0.36 | 0.44 | 0.15 | 0.49 |
| SEC | kW/TR | 3.64 | 4.11 | 13.74 | 5.07 |
| Heat Rejected | kJ/hr | 1081 | 1324 | 440 | 1490 |

Observation:

- ❖ All the AC units are older than 14 years with 2/3-star ratings.
- ❖ The specific energy consumption (SEC) is in the range of 3–14 KW/TR, which is higher than the rated value. (Refer to ECM 3.6 for replacing the older AC units with energy-efficient ones.)
- ❖ The AC units are operating at a set point temperature of 24 °C, which is a good practice.
- ❖ Admin building server room AC's operating with timer, which is good practice.

4.4 Pumps

- ❖ There are bore well pumps (5.5 KW) each and a sump pump near the sump tank (5.5 KW) is installed.
- ❖ In a sewage treatment plant (STP), a filter feed-back pump with two no's (5 HP each) is installed, operating for 2 hours per day.
- ❖ STP water pump to supply water to all blocks (3.7 KW) installed
- ❖ During the audit, sample-based pump assessments were done (flow, pump details, and power measurement).
- ❖ The performance assessment is given below.

Table 14. Performance assessment for Bore well pumps

| Design Parameter | Units | Borewell-1 | Sump tank Pump | Borewell-3 |
|-------------------------------------------------------------------------------------|---------------------|------------|----------------|------------|
| Manufacturer | - | - | - | - |
| Model | - | HRF 19/30 | HRF 19/30 | HRF 19/30 |
| Motor Power | kW | 3.7 | 3.7 | 3.7 |
| Flow | m ³ /hr. | - | - | - |
| Head | m | - | - | - |
| Speed | rpm | - | - | - |
| Motor Efficiency | % | 86% | 86% | 86% |
| Actual Measurement | | | | |
| Operating Hours | hrs. | 4 | 4 | 4 |
| Actual Power | kW | 5.9 | 4.4 | 3.7 |
| Suction Pressure | kg/cm ² | 0 | 0 | 0 |
| Discharge Pressure | kg/cm ² | 9 | 9 | 9 |
| Flow | m ³ /hr. | 9.8 | 9.2 | 5.2 |
| Throttling | | | | |
| Suction Control Valve open | % | 100% | 100% | 100% |
| Suction Control Valve close | % | 0% | 0% | 0% |
| Discharge Control Valve open | % | 100% | 100% | 100% |
| Discharge Control Valve close | % | 0% | 0% | 0% |
| Variable Speed Drive | | | | |
| VFD Installed | (Yes / No) | No | No | No |
| Operating Frequency | Hz | - | - | - |
| Calculation | | | | |
| Head(H)= Discharge Pressure-(-Suction Pressure)*10 | m | 90 | 90 | 90 |
| Hydraulic Power = (Q _{in} m ³ /hr*1000/3600)*H*9.81/ 1000 | kW | 2.4 | 2.3 | 1.3 |
| Combined efficiency = (Hyd Power/Actual power)*100 | % | 41% | 51% | 34% |
| Pump efficiency = (Comb Eff/Motor Efficiency)*100 | % | 47% | 60% | 40% |
| Motor Loading | % | 137% | 102% | 86% |


Observation:

- ❖ Borewell pump-1 near canteen is overloaded by 137%.

5.0 Electrical Graphs

5.1 Main incomer 500 KVA Transformer


Figure 12. Voltage profile for main incomer



Observations:

- ❖ The main incomer panel voltage varies from 409 V to 418 V. The average voltage is 413 V during recording time.
- ❖ The main incomer voltage profile value is within the limit specified as per the IEC 60038-2009 ($\pm 10\%$) standard.


Figure 13. Current profile for main incomer



Observations:

- ❖ The main incomer the current varies from 28A to 141A during recording time.
- ❖ During recording main incomer load is less.


Figure 14. Power profile for main incomer



Observations:

- ❖ The Power of the main incomer varies from -37 kW to 59 kW. Average power is 18W during recording time.

Figure 15. Current Unbalance in main incomer



Observations:

- ❖ The main incomer current Unbalance is Average 25%.it is high in value.
- ❖ Distribute the loads equally in loads side.



GREEN AUDIT

Przebieg
Przebieg

CEMILIA SPOŁACZNA Z OGRANICZONĄ ODPOWIEDZIALNOŚCIĄ


6.0 Green Audit

A green audit is a process of systematic identification, quantification, recording, reporting, and analysis of components of the environmental diversity of an institution. It aims to analyze environmental practices within and outside the concerned sites, which will have an impact on the eco-friendly ambience. A green audit can be a useful tool for a college to determine how and where energy, water, or other resources are used the most. The college can then consider how to implement conservation measures and make savings. It can also be used to determine the type and volume of waste, which can be used for a recycling project or to improve a waste minimization plan. Green audits can be a highly valuable tool for colleges in a wide range of ways to improve their environmental and economic performance and reputation while reducing waste and operating costs. The main objective of the green audit is to promote environmental management and conservation on the college campus.

6.1 Waste Management

Waste management is a process that determines the kind and volume of waste that an organization produces. Different types of waste generated inside the institution are represented in the below block diagram.

Figure 16. Types of waste generated




Observations

- ❖ Paper waste from office/class and labs are stored and sent for recycling
- ❖ E-Waste is collected, stored, and disposed with help of Moogambigai Metal Refineries, Mangalore.
- ❖ Incinerator is fixed for safe disposal of sanitary waste.
- ❖ Separate bins are not there for bio-degradable and non-biodegradable waste.
- ❖ No quantification of waste daily or monthly basis.
- ❖ Other solid waste is collected and disposed through the municipal corporation.
- ❖ DG changed oil is taken back by DG service person.
- ❖ Garden waste is collected and dumped in backyard.
- ❖ Waste from chemistry lab is going to same drain.
- ❖ Steel glasses are provided for drinking water.
- ❖ Cleaning and collecting wastes at frequent intervals.
- ❖ Food waste is being disposed to local pig rearing units.
- ❖ Making pens with waste paper.

Table 15. Waste generation

| S.NO | TYPE OF WASTE | QUANTITY IN KG/DAY | QUANTITY IN KG/YEAR |
|-------|----------------------------------------------------|--------------------|---------------------|
| 1 | Paper | 5 | 1800 |
| 2 | Plastic | 1 | 360 |
| 3 | Bio Waste - food waste (300 Days – hostel days) | 60 | 18000 |
| 4 | Bio Waste - crop waste | 10 | 3600 |
| 5 | E-Waste | 0.44 | 158.4 |
| 6 | Construction Debris | 3 | 1080 |
| Total | | 79.44 | 21998.4 |

Figure 17. Total waste generation



- ❖ The campus generates nearly 79.44 kg of waste every day, including paper, construction debris, plastic, e-waste, and bio-waste (food waste, leaves, grass, etc.). According to per-month data, 72% of waste comes from food, 14% organic (both dry and wet leaves), 7% from paper, 4% from construction debris, 2% from plastic, and 1% from e-waste.
- ❖ As per our observations, the college should take the initiative to reduce their overall waste. Most of the waste comes from used food from the hostel or canteen and papers in classrooms.
- ❖ Waste from construction debris is found around the campus. So, this waste can be effectively reused for landscaping. Only a minimum amount of e-waste is generated inside the campus, and it is disposed of through Moogambigai Metal Refineries, Mangalore.
- ❖ The incinerator is fixed for the safe disposal of sanitary waste. Separate bins should be placed for biodegradable and non-biodegradable waste disposal.
- ❖ Educate the students on how to use the bins and their purpose. Maintain proper records on the type of waste, quantity of waste, and vendor details on a daily basis.
- ❖ Establish vermicompost pits for dumping garden and wet waste from campus. Paper waste can be reduced by using both sides before disposal.
- ❖ The college should set a yearly goal to lower waste generation. Nearly 1.8 tons of paper is sent to recycling every year. You can minimize paper by going for digital practices (electronic signatures

and digital document management solutions). To become a zero-waste campus, waste generation must be monitored.

- ❖ Awareness programs are to be conducted among staff and students on effective use of resources and contributing to the environment.

Recommendations

- ❖ Reduce the amount of waste that is produced in classrooms.
- ❖ Keep biodegradable and non-biodegradable waste bins for segregation of waste.
- ❖ Establish vermicompost for composting dry leaves, green waste, and wet waste.
- ❖ Install a mini biogas production unit to convert food waste into biogas.
- ❖ Use construction debris waste for landscaping.
- ❖ Maintain records for the type of waste and the amount of waste disposed of.
- ❖ Use concrete blocks from the civil lab for landscaping applications.
- ❖ A proper record should be maintained for the type of waste, its quantity, and how it's disposed.
- ❖ Keep a proper record of the DG oil replaced and ensure proper disposal.
- ❖ Chemistry lab waste should be handled effectively (acid-base neutralization).
- ❖ LPG Savings by Installing biogas plant for the food waste produced from canteen is given in (section 3.5.2).
- ❖

Figure 18. *Strategies need to be implemented*



6.2 Water Management

A water audit is a qualitative and quantitative analysis of water consumption to identify means of reducing, reusing, and recycling water. A water audit is a method of quantifying all the flows of water in a system to understand its usage and improve water conservation. A water audit gives an idea of the amount of water that is consumed in the college for activities like washing hands, drinking in the laboratories, watering the garden, and flushing toilets and urinals. From the results obtained, students and staff will consider better ways to improve water conservation throughout the building and on the college campus. It is therefore essential that any environmentally responsible institution examine its water use practices. A water audit provides an overview of water use trends, the effectiveness of conservation measures, and potential cost and water savings.

Observations

- ❖ Two borewells are available on campus to meet the water requirement.
- ❖ Overhead tanks of 2X10,000 litres in the admin block, 1X10,000 in the EC block, 1X10,000 in the civil and mechanical blocks, 1X10,000 in the AIDS block, 1X5,000 in the workshop block, 1X10,000 in the library block, 2X10,000 in the canteen, 2X10,000 in the girls hostel, and 2X10,000 in the boys hostel are installed. The total capacity of the installed water tanks is 1,25,000 litres.
- ❖ Waste water is collected and treated in an STP plant with a capacity of 74,000 litres.
- ❖ Overhead tanks of 7 x 10000 litres for storing and utilizing STP water are installed in all blocks.
- ❖ Exact consumption details are not available as water meters are not installed.
- ❖ v. A demo A rainwater harvesting system is installed in the civil and mechanical blocks.
- ❖ Rainwater flowing off of places near the admin block is used to recharge a bore well.
- ❖ In all blocks, the overhead tanks are overflowing.
- ❖ A RO water system is provided for drinking water.
- ❖ Many taps in both boys and girls rest rooms in both academic and hostel blocks are not properly closed.
- ❖ The approximate water consumption is 100,000 litres per day.
- ❖ Periodic testing of raw water and drinking water is done.
- ❖ Open-pipe irrigation is used on campus.
- ❖ Around 300 taps are installed on the campus.

- ❖ Water flow varies from 5 lpm to 12 lpm.
- ❖ Potable water is used for cleaning buses.

Water from a fully open valve pipe of diameter 10mm is used for more than 4 hours per day at a rate of 10 lpm to clean utensils in the kitchen of the canteen.

Table 16. Water test results

| Sl.NO | Parameters | Unit | Boys Hostel | Girls Hostel | Canteen | BIS: 10500-2012 Desirable Limit |
|-------|-------------------------------------|------|-------------|--------------|---------|---------------------------------|
| 1 | Ph | - | 6.98 | 7.35 | 6.75 | 6.5-8.5 |
| 2 | Total Hardness as CaCO ₃ | mg/l | 88 | 88 | 84 | 200 Max |
| 3 | Turbidity | NTU | 1.4 | 0.9 | .98 | 1 Max |
| 4 | TDS | mg/l | 176 | 196 | 176 | 500 Max |
| 5 | Conductivity | mg/l | 265.6 | 285.6 | 285.6 | - |
| 6 | Chlorides | mg/l | 21.99 | 27.99 | 19.99 | 250 Max |
| 7 | Nitrate Nitrogen | mg/l | Nil | Nil | Nil | Nil |
| 8 | Ammonical Nitrogen | mg/l | Nil | Nil | Nil | Nil |
| 9 | H2S (Bacteriological Contamination) | - | Nil | Nil | Nil | Nil |

Figure 19. STP Water Quality test report

SHRI MADHWA VADIRAJA INSTITUTE OF TECHNOLOGY AND MANAGEMENT
 A Unit of the Government Engineering College, Udupi
 Approved by the Government of Karnataka, Government of India
 Approved by the Government of Karnataka, Government of India
 Approved by the Government of Karnataka, Government of India

SMVITH
 20 April 2023

STP Treated Water
 SMVITH, Bussanaki,
 Udupi.

Dear Sir,
 Sub: Water Quality Testing
 Ref: Your request dated 09-04-2023

In reference to the above, we have conducted the following tests on the sample supplied by you. The test report is as below.

| Sl. No. | Tests | Results |
|---------|------------------------------|---------|
| 1 | pH Value | 7.50 |
| 2 | Total Dissolved Solids, mg/l | 293.00 |
| 3 | COD (mg/l) | 22.00 |
| 4 | COD (mg/l) | 314.90 |
| 5 | Total Dissolved Solids, mg/l | 381.21 |
| 6 | Oil and grease, mg/l | Nil |

Lab In-Charge
 Department of Civil Engineering
 (Dr. Vasanta & Co)

Coordinator
 Testing & Consultancy Civil-CEI
 Mr. Rishan S. Prabhu

Head
 Department of Civil Engineering
 (Dr. Deepika S. V.)
 Professor & Head

Figure 20. Water Quality test report canteen

SHRI MADHWA VADIRAJA INSTITUTE OF TECHNOLOGY AND MANAGEMENT
 Institute of the South Indian Institute of Technology (SIIT) Group
 Accredited by AICTE, Autonomous Institute with B Grade - (15/06/2015)
 Approved by AICTE, New Delhi & Bangalore for UGC & Distance Education
 Headquarters: Nanjar, Tumkur - 577115, Udupi District, Karnataka.

SMVITH/TCU/2023-24/0129 30 July 2023

Canteen
 SMVITH, Bantwal
 Udupi.

Dear Sir,
 Sub - Water Quality Testing
 Ref - Your request dated 09-07-2023

With reference to the above, we have conducted the following tests on the sample supplied by you. The test report is as below.

| Sl. No. | Tests | Results | IS: 10500-2012 Desirable limit |
|---------|--------------------------------------------------|---------|-----------------------------------|
| 1 | pH Value | 6.95 | 6.5 to 8.5 |
| 2 | Total Hardness as CaCO ₃ , mg/l | 16 | 200 max |
| 3 | Turbidity, NTU | 2.98 | 5 max |
| 4 | Total dissolved solids, mg/l | 154.00 | 500 max |
| 5 | Conductivity, mg/l | 275.8 | - |
| 6 | Chlorides, mg/l | 28.99 | 250 max |
| 7 | Nitrate Nitrogen, mg/l | NA | NA |
| 8 | Ammonical Nitrogen | NA | NA |
| 9 | H ₂ S (Bacteriological Concentration) | NA | NA |

Lab In-Charge
 Department of Civil Engineering
 (Dr. Deepika B V)

Coordinator
 Testing & Consultancy Cell-CE3
 (Mr. Roshan S. Kottan)


Head
 Department of Civil Engineering
 (Dr. Deepika B V)

Pw/Work & Hrs
 18.04.2023
 18.04.2023

Figure 21. Best Practices



Figure 22. Processes in need of improvement



Recommendations

- ❖ Install water meters at the bore well side for details on the quantity of water pumped from the source and on all hostels and academic blocks to monitor the overall consumption of water inside the campus and take necessary actions when required.
- ❖ Install a rainwater harvesting system for all blocks.
- ❖ Install an automatic water tank overflow controller to arrest the overflow of water.
- ❖ Use aerated taps to conserve more water.
- ❖ Conduct awareness programs on water conservation for students. Place posters like "Save Water" in all blocks.
- ❖ Adjust the main pipe regulator to reduce the water flow to 5 lpm in handwashing areas.
- ❖ Install dishwashing machines and nozzles in the canteen to clean utensils and minimize water consumption.
- ❖ Check the option for a drip irrigation system.
- ❖ Planting native trees in place of exotic plants will reduce the water requirement for irrigation.
- ❖ Replant invasive grass lawns with native grass, which will conserve water.

7.0 Biodiversity

A biodiversity audit ensures the greenery and sustainability of the campus. The biodiversity audit is conducted to analyze the present biodiversity status of the college and to propose plans to enhance the existing biodiversity. In this audit, the focus has been on the assessment of the present status of diversity, which includes trees, shrubs, birds, and other habitats on and around campus. Efforts are also made by the college authorities to conserve nature. In this audit, student volunteers were involved to identify the flora and fauna present on campus. The focus is also given on pollution control methodology, best practices for environmental conservation, etc. This audit gives recommendations to the college for the conservation and protection of natural vegetation and animal life by involving students and faculty members to make the institute's campus biodiversity rich.

Observations

- ❖ Nearly 53 floral species are seen around the campus.
- ❖ Around 700 mature trees of various species are found.
- ❖ 25 faunal species are found on the campus.
- ❖ The faunal diversity is lower compared to the floral diversity.
- ❖ Many exotic trees are found on campus.
- ❖ Flowering, medicinal, and herbal plants are less common compared to common native plants.
- ❖ Rank holders are planting trees on campus.

Table 17. Floral species in the campus

| S.No | Common Name | Scientific Name |
|------|---------------------|---------------------------|
| 1 | Mauritius Hemp | Furcraea Foetida |
| 2 | Oleander Spurge | Euphorbiaceae |
| 3 | Kudzu | Pueraria Montana |
| 4 | Asian Spyder Flower | Clomeviscosa |
| 5 | Prostrate Shrub | Euphorbiaceae |
| 6 | Dogbanes | Apocynaceae |
| 8 | Garden Croton | Codiaeum Variegatum |
| 9 | Travers Palm | Ravenala Madagascariensis |
| 10 | Bermuda Grass | Cynodon Dactylon |
| 11 | African Arrowroot | Canna Indica |
| 12 | Tulsi | Ocimum Tenuiflorum |


| S.No | Common Name | Scientific Name |
|------|------------------------|----------------------------|
| 13 | Dumb Cane | Dieffenbachia Seguine |
| 14 | Santa Maria | Parthenium Hysterophorus |
| 15 | Cape Periwinkle | Catharanthus Roseus |
| 16 | Dunchi | Legume Sesbania Bispinosa |
| 17 | Indian Almond | Terminalia Catappa |
| 18 | Pongam | Milletia Pinnata |
| 19 | Coconut | Cocos Nucifera |
| 20 | Polyalthia | Monoon Longifolium |
| 21 | Broom Rain | Albizia Lebbeck |
| 22 | Mango | Mangifera Indica |
| 23 | Orchid | Orchidaceae |
| 24 | Indian Banyan | Ficus Benjamina |
| 25 | Date Palm | Phoenix Dactylifera |
| 26 | Hibiscus | Hibiscus Rosa-Sinensis |
| 27 | Night-Blooming Jasmine | Cestrum Nocturnum |
| 28 | Chicoo | Manilkara Zapota |
| 29 | Crape Jasmine | Tabernaemontana Divaricata |
| 30 | Golden Trumpet | Allamanda Cathartica |
| 31 | Golden Dewdrop | Duranta Erecta |
| 32 | Pitanga | Eugenia Uniflora |
| 33 | Golden Tree | Cassia Fistula |
| 34 | Queen's Crepe | Lagerstroemia Speciosa |
| 35 | Guava | Psidium Guajava |
| 36 | Jackfruit | Artocarpus Heterophyllus |
| 37 | Banana | Musa Acuminata |
| 38 | Sugar Cane | Saccharum Officinarum |
| 39 | Breadfruit | Artocarpus Altilis |
| 40 | Papaya | Carica Papaya |
| 41 | Indian Sandalwood | Santalum Album |
| 42 | Calabura | Muntingia Calabura |
| 43 | Chinese Apple | Malus Prunifolia |
| 44 | Java Plum | Syzygium Cumini |
| 45 | Cashew | Anacardium Occidentale |
| 46 | Acacia | Vachellia Nilotica |

| S.No | Common Name | Scientific Name |
|------|---------------|--------------------|
| 47 | Neem | Azadirachta Indica |
| 48 | Jujube | Ziziphus Jujuba |
| 49 | Chinese Ixora | Ixora Chinensis |
| 50 | Gooseberry | Ribes Uva-Crispa |
| 51 | Rose | Rosa Indica |
| 52 | Yellow Elder | Tecoma Stans |
| 53 | Bamboo | Bambusa Vulgaris |

Table 18. Faunal species in the campus

| Si.No | Common Name | Scientific Name |
|-------|--------------------|------------------------|
| 1 | Common Hawk-Cuckoo | Hierococcyx Varius |
| 2 | Asian Koel | Eudynamys Scolopaceus |
| 3 | House Sparrow | Passer Domesticus |
| 4 | Lizard | Lacertilia |
| 5 | Pigeon | Columbidae |
| 6 | Ants | Formicidae |
| 7 | Butterflies | Rhopalocera |
| 8 | Rat | Rattus |
| 9 | Snake | Serpentes |
| 10 | Beetles | Coleoptera |
| 11 | Dragonfly | Anisoptera |
| 12 | Peacock | Pavo Cristatus |
| 13 | Indian Myna | Acridotheres Tristis |
| 14 | Hummingbirds | Trochilidae |
| 15 | Starling | Sturnus Vulgaris |
| 16 | Cat | Felis Catus |
| 17 | Dog | Canis Lupus Familiaris |
| 18 | Frog | Anura |
| 19 | Millipede | Diplopoda |
| 20 | Common Earthworm | Lumbricina |
| 21 | Bug | Hemiptera |
| 22 | Crow | Corvus Spp |

Figure 23. *Flora and Fauna in the campus*



Recommendations

- ❖ To maintain the college campus green and eco-friendly, more trees need to be planted so that carbon neutrality can be maintained.
- ❖ Food and water pots are kept inside the campus for feeding the animals and birds.
- ❖ Plant more native trees rather than exotic species to maintain plant diversity.
- ❖ Review the list of trees planted in the garden periodically, allot numbers to the trees and keep records. Assign scientific names to the trees.
- ❖ Create awareness of environmental sustainability among students and take actions to ensure environmental sustainability.
- ❖ Indoor plantation to be encouraged, Bonsai can be planted in corridor to bond a relation with nature.
- ❖ All trees in the campus should be named scientifically.
- ❖ Establish drip irrigation system for watering plants and trees to save more water.
- ❖ Plant more medicinal plants and fruit bearing trees to maintain plant diversity.
- ❖ The faunal diversity is low; however, it can be improved by planting more flowering and fruit bearing plants.

8.0 Carbon Foot Print Analysis

Carbon footprint due to transport, energy consumption and internal diesel consumption is analysed, and the details are given below.

Table 19. Carbon Foot Print Analysis

| Sl.No | Description | Type of Fuel and their CO ₂ Conversion Process | | | |
|-------|---------------------------------------------------------------------|-----------------------------------------------------------|-----------------------------|------------------------|----------------|
| | | Fuel Consumption | | | |
| | | Electricity kWh | Diesel (Vehicle + DG) Litre | Petrol (Vehicle) Litre | LPG kg |
| 1 | Total Annual Consumption | 215693 | 27655 | 430 | 6400 |
| 2 | CO ₂ Emission (Tons/Annum) | 177 | 73 | 1 | 19 |
| 3 | Total CO₂ Emission (Tons/Annum) | | | | 270 (↑) |
| 4 | No. of Matured Trees Available | | | | 700 |
| 5 | CO ₂ offset due to Trees (Tons/Annum) | | | | 15.26 (↓) |
| 6 | Annual Energy Exported from SPV Plant (kWh) | | | | 29982 |
| 7 | CO ₂ offset due to export Solar Power Plant (Tons/Annum) | | | | 25 (↓) |
| 8 | CO ₂ Emission per (Tons/Annum) currently | | | | 230 (↑) |

| Sl.No | Description | Type of Fuel and their CO ₂ Conversion Process | | | |
|-------|---------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|-----------------------------|------------------------|----------|
| | | Fuel Consumption | | | |
| | | Electricity kWh | Diesel (Vehicle + DG) Litre | Petrol (Vehicle) Litre | LPG kg |
| 9 | Expected Reduction of Annual Electricity Consumption after Implementing Proposed Energy Conservation Measures (kWh) | | | | 95438 |
| 10 | CO ₂ offset after implementing ECM (Tons/Annum) | | | | 78.3 (↓) |
| 11 | Expected Reduction of Annual LPG Consumption after Implementing Proposed ECM (kgs) | | | | 1232 (↓) |
| 12 | CO ₂ Offset after implementing biogas plant instead of LPG (Tons/Annum) | | | | 3.7 (↓) |
| 13 | Amount of CO ₂ to be Offset (Tons/Annum) | | | | 82 (↔) |
| 14 | Per Capita CO ₂ Consumption (Tons/Annum) | | | | 0.116 |

Observations

- ❖ Major carbon emission is for the electricity usage.
- ❖ Encourage carpooling and usage of cycles planting more trees will help to reduce net carbon emission.



Bigeta Energy Solutions LLP is an ISO 9001:2015 certified, Energy & Sustainability Management company. We provide consultancy services in Energy Audits & Assessments, Electrical Power Assessment, Electrical Safety Assessment, ETAP Analysis, Measurement & Verification, Thermal Imaging, Energy Data Analytics, Green Building, ISO 50001 EnMS and Training. We are a team of BEE accredited energy auditor, BEE certified energy auditor, energy manager, Certified Measurement and Verification Professional (CMVP), ISO 50001 lead auditor, IGBC Accredited Professional (IGBC AP), GRIHA Certified Professional and power quality professionals committed to giving most promising solutions to customers to save energy and attain sustainability.



Registered Office

Bigeta Energy Solutions LLP

K 206, Confident Atik, Sompura Gate, Sarjapura,
Bangalore-562 125, Karnataka
info@bigetaenergy.com, +91 99 00 591 000
www.bigetaenergy.com

Principa

Principal

SHRI MADHWA VADIRAJA
INSTITUTE OF TECHNOLOGY & MANAGEMENT
Vishwothama Nagar, Udipi Dist.
BANTARGAL - 574 115